



www.haleyaldrich.com

**REPORT ON
2017 ANNUAL GROUNDWATER MONITORING AND
CORRECTIVE ACTION REPORT
A.B. BROWN GENERATING STATION
WEST FRANKLIN, INDIANA**

by Haley & Aldrich, Inc.
Greenville, South Carolina

for Southern Indiana Gas and Electric Company (SIGECO)
Evansville, Indiana

File No. 129420-003
January 2018

Annual Groundwater Monitoring Report Summary

Haley & Aldrich, Inc. (Haley & Aldrich) has prepared this 2017 Annual Groundwater Monitoring Corrective Action Report for the A.B. Brown Generating Station (ABB). This 2017 Annual Report was developed to comply with the United States Environmental Protection Agency (USEPA) Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals (CCR) from Electric Utilities, 40 CFR Part 257, Subpart D dated 17 April 2015 (Rule), specifically subsection §257.90(e)(1) through (5). Southern Indiana Gas and Electric Company (SIGECO) operates the existing coal combustion residuals (CCR) management unit referred to as Sedimentation pond at ABB located in Posey County, Indiana near the community of West Franklin. This CCR unit is subject to the Rule since it was active as of the effective date of the Rule.

This annual report addresses the CCR management unit, referred to as Sedimentation pond, at ABB, as described in the Groundwater Monitoring Program report, which was certified and placed in the facility's operating record on October 17, 2017 as required by §257.105(h)(2) and posted on the facility's website on November 16, 2017 as required by §257.107(h)(2).

To report on the activities conducted during the prior calendar year and document compliance with the Rule, the specific requirements listed in §257.90(e)(1) through (5) are provided below in bold/italic type followed by a short narrative addressing how that specific requirement was met.

§257.90 APPLICABILITY

§257.90(e) Annual groundwater monitoring and corrective action report. For existing CCR landfills and existing CCR surface impoundments, no later than January 31, 2018, and annually thereafter, the owner or operator must prepare an annual groundwater monitoring and corrective action report. For new CCR landfills, new CCR surface impoundments, and all lateral expansions of CCR units, the owner or operator must prepare the initial annual groundwater monitoring and corrective action report no later than January 31 of the year following the calendar year a groundwater monitoring system has been established for such CCR unit as required by this subpart, and annually thereafter. For the preceding calendar year, the annual report must document the status of the groundwater monitoring and corrective action program for the CCR unit, summarize key actions completed, describe any problems encountered, discuss actions to resolve the problems, and project key activities for the upcoming year. For purposes of this section, the owner or operator has prepared the annual report when the report is placed in the facility's operating record as required by §257.105(h)(1).

As required, this annual report documents the status of the groundwater monitoring program for the CCR management unit at ABB and summarizes key actions completed during the prior calendar year.

At a minimum, the annual groundwater monitoring and corrective action report must contain the following information, to the extent available:

§257.90(e)(1) AERIAL IMAGE OF GROUNDWATER MONITORING PROGRAM

§257.90(e)(1) A map, aerial image, or diagram showing the CCR unit and all background (or upgradient) and downgradient monitoring wells, to include the well identification numbers, that are part of the groundwater monitoring program for the CCR unit;

As required by §257.90(e)(1), maps showing the location of the Sedimentation pond and associated upgradient and downgradient monitoring wells are included in this report as **Figure 1**. In addition, this information is presented in the Groundwater Monitoring Program report prepared for ABB, which was placed in the facility's operating record on October 17, 2017 as required by §257.105(h)(2).

§257.90(e)(2) ADJUSTMENTS TO GROUNDWATER MONITORING PROGRAM

§257.90(e)(2) Identification of any monitoring wells that were installed or decommissioned during the preceding year, along with a narrative description of why those actions were taken;

To comply with the requirements of §257.91, a groundwater monitoring network of five (5) wells were installed for the Sedimentation pond at ABB. Details of the design, and construction of the monitoring wells are summarized in Table 1. Additional description of the monitoring network is presented in the Groundwater Monitoring Program report, which was placed in the facility's operating record on October 17, 2017, as required by §257.105(h)(2). None of the wells installed to monitor groundwater quality upgradient and downgradient of the Sedimentation pond were decommissioned in 2017.

§257.90(e)(3) SUMMARY OF GROUNDWATER ANALYSIS

§257.90(e)(3) In addition to all the monitoring data obtained under §257.90 through §257.98, a summary including the number of groundwater samples that were collected for analysis for each background [upgradient] and downgradient well, the dates the samples were collected, and whether the sample was required by the detection monitoring or assessment monitoring programs;

In accordance with §257.94(b), a minimum of eight independent samples from each upgradient and downgradient monitoring well were collected prior to October 17, 2017. A summary of the groundwater monitoring program for the Sedimentation pond, including the analytical results for the Appendix III and Appendix IV list of constituents, is presented in **Table 2** of this report. All the samples obtained were required by the detection monitoring program.

§257.90(e)(4) CURRENT GROUNDWATER MONITORING PROGRAM

§257.90(e)(4) A narrative discussion of any transition between monitoring programs (e.g., the date and circumstances for transitioning from detection monitoring to assessment monitoring in addition to identifying the constituent(s) detected at a statistically significant increase over background levels);

Consistent with §257.90(e), the 2017 annual report documents groundwater related activities conducted during the prior calendar year at the Sedimentation pond. The statistical analysis of the initial minimum eight rounds of groundwater sampling was completed by January 15, 2018 as required. This statistical analysis relied on the use of tolerance intervals as originally certified on October 17, 2017. The results of this statistical analysis identified statistically significant increases (SSI) of Appendix III constituents in one or more wells monitoring the uppermost aquifer downgradient of the Sedimentation pond. Consistent with §257.94(e)(2), SIGECO is evaluating options to demonstrate that a source other than the CCR unit caused the SSI and will provide a narrative discussion of any transition between monitoring programs (e.g., the date and circumstances for transitioning from detection monitoring to assessment monitoring in addition to identifying the constituent(s) detected at a statistically significant increase over background levels), as appropriate, in subsequent annual reports.

§257.90(e)(5) OTHER REQUIRED INFORMATION

§257.90(e)(5) Other information required to be included in the annual report as specified in §257.90 through §257.98.

This initial Annual Report documents activities conducted to comply with Sections §257.90 through §257.94 of the Rule. There are no applicable requirements from Sections §257.95 through §257.98.

Attachments

Table 1. Groundwater Monitoring Well Location and Construction Details

Table 2. Summary of Analytical Results

Figure 1. Monitoring Well Network

\\\haleyaldrich.com\\share\\grn_common\\129420 Vectren\\AB Brown\\Annual Report\\Sedimentation Pond\\Text\\ABB_SP_Annual_GW_Report_F.docx

TABLES

TABLE I

Page 1 of 1

GROUNDWATER MONITORING WELL LOCATION AND CONSTRUCTUON DETAILS

A.B. BROWN GENERATING STATION SEDIMENTATION POND

MOUNT VERNON, INDIANA

Well	CCR Unit	Date Installed	Easting	Northing	Top of Pad Elevation (ft msl)	Top of Riser Elevation (ft msl)	Surface Grout (ft bgs)	Bentonite (ft bgs)	Sand Pack (ft bgs)	Screen Zone (ft bgs)	Screen Length (ft)	Well Radius (in)
CCR-SP-1	Sediment Pond	March 2016	2770030.26	970981.89	403.90	403.51	0.0 - 6.0	6.0 - 8.0	8.0 - 20.0	10.0 - 20.0	10	2.00
CCR-SP-2	Sediment Pond	March 2016	2769939.51	970887.25	403.60	403.23	0.0 - 6.0	6.0 - 8.0	8.0 - 20.0	10.0 - 20.0	10	2.00
CCR-SP-3	Sediment Pond	March 2016	2770027.64	970735.02	403.90	403.57	0.0 - 6.0	6.0 - 8.0	8.0 - 20.0	10.0 - 20.0	10	2.00
CCR-BK-1R	Background	March 2016	2770919.08	974083.40	480.10	483.39	0.0 - 50.0	50.0 - 52.0	52.0 - 64.0	54.0 - 64.0	10	2.00
CCR-BK-2	Background	March 2016	2769728.14	972854.33	427.50	430.60	0.0 - 11.5	11.5 - 13.5	13.5 - 25.5	15.5 - 25.5	10	2.00

Notes:

bgs = below ground surface

ft = feet

in = inches

msl = mean sea level

Datum of Elevations in NAVD 88

TABLE II
SUMMARY OF ANALYTICAL RESULTS
A.B. BROWN GENERATING STATION
MOUNT VERNON, INDIANA

Location Group	Upgradient									CCR-BK-1R CCR-BK-1R-20171116
	CCR-BK-1R CCR-BK-1-20160811	CCR-BK-1R CCR-BK-1-20161027	CCR-BK-1R CCR-BK-1R-20161107	CCR-BK-1R CCR-BK-1R-20161206	CCR-BK-1R CCR-BK-1R-20170207	CCR-BK-1R CCR-BK-1R-20170407	CCR-BK-1R CCR-BK-1R-20170606	CCR-BK-1R CCR-BK-1R-20170928		
Location Name										
Sample Name										
Sample Date	08/11/2016	10/27/2016	11/07/2016	12/06/2016	02/07/2017	04/07/2017	06/06/2017	09/28/2017		
Lab Sample ID	180-57528-14	180-60271-6	180-60609-5	180-61491-18	180-63324-18	180-65040-1	180-67229-16	180-70809-15		
Water Level (ft amsl)	463.50	422.65	423.39	422.39	421.39	425.39	425.39	425.39		
Monitoring Program	Baseline	Baseline	Baseline	Baseline	Baseline	Baseline	Baseline	Baseline		Detection
Field Parameters										
Temperature (Deg C)	20.68	15.88	20.42	11.36	14.52	14.94	17.06	24.01		10.95
Turbidity, Field (NTU)	-	-	-	-	-	-	-	0.76		
Dissolved Oxygen, Field (mg/L)	5.15	5.85	5.89	7.03	5.98	5.43	6.28	6		8.82
Conductivity, Field (mS/cm)	0.3475	0.38255	0.36566	0.32748	0.3703	0.31348	0.35539	0.35718		0.40797
ORP, Field (mv)	222	223.99	116.48	52.8	131.91	98.13	266.28	147.09		47.02
Turbidity, Field (NTU)	17.39	19.19	10.68	97.13	6.47	17.2	24.08	-		131.33
pH, Field (su)	6.8	6.95	7.02	7.14	6.87	7.22	6.95	6.88		7.13
Detection Monitoring - EPA Appendix III Constituents (mg/L)										
Boron, Total	0.014 U	0.02 U	0.023 U	0.02 U	0.08 U	0.019 J	0.026 J	0.015 J+		0.041 J
Calcium, Total	36	41	38	36	34	35	34	35		39
Chloride (mg/L)	R	2.4	1.5	2.3	2.3	2.7	2.1	2.2		2.6
Fluoride (mg/L)	R	0.35	0.32	0.35	0.3	0.38	0.3	0.35 J+		0.3
Sulfate (mg/L)	R	26	21	26	27	28	25	25		26 J-
pH (lab) (su)	7.4 J	7.5 J	7 J	6.9 J	7.2 J	7.2 J	7.1 J	7.1 J		7.8 J
Total Dissolved Solids (TDS) (mg/L)	220	210	220	200	230	250	270	210		210
Assessment Monitoring - EPA Appendix IV Constituents (mg/L)										
Antimony, Total	0.002 U	0.002 U	0.000056 J	0.002 U		0.00045 J				
Arsenic, Total	0.0011	0.00021 J	0.001 U	0.00031 J	0.00094 J	0.00095 J	0.00047 J	0.0025 J+		0.0015 J+
Barium, Total	0.048	0.035	0.037 J-	0.031 J-	0.038	0.04	0.038	0.032 J-		0.082 J-
Beryllium, Total	0.00012 J	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U		0.001 U
Cadmium, Total	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U		0.001 U
Chromium, Total	0.0025	0.00046 J	0.00087 J	0.00071 J	0.003	0.0026	0.0019 J	R		0.0027 J+
Cobalt, Total	0.0028	0.00076	0.00051	0.0005 U	0.0011	0.001	0.00062	R		0.0022
Lead, Total	0.00082 J	0.00024 J	0.000079 J	0.000096 J	0.00099 J	0.00092 J	0.00052 J	0.001 U		0.0008 J
Lithium, Total	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U		0.0086 J
Molybdenum, Total	0.0025 J	0.005 U	0.005 U	0.0015 J	0.0017 J	0.0025 J	0.0015 J	R		0.0034 J
Selenium, Total	0.00067 J	0.005 U	0.00037 J	0.00051 J	0.005 U	0.005 U	0.005 U	0.005 U		0.005 U
Thallium, Total	0.000038 J	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U		0.001 U
Mercury, Total	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 U		0.0002 U
Fluoride (mg/L)	R	0.35	0.32	0.35	0.3	0.38	0.3	0.35 J+		0.3
Radiological (pCi/L)										
Radium-226	0.0484 U ± 0.104	0.0760 U ± 0.210	R	0.303 U ± 0.296	0.142 ± 0.0913	0.280 ± 0.0981	0.177 J ± 0.0924	R		0.165 ± 0.0740
Radium-228	0.0724 UJ ± 0.514	0.191 U ± 0.217	-0.0566 U ± 0.222	0.179 U ± 0.238	-0.0934 U ± 0.194	0.177 U ± 0.257	0.337 ± 0.257	0.173 U ± 0.226		0.388 U ± 0.268
Radium-226 & 228	0.121 UJ ± 0.525	0.267 U ± 0.302	R	0.482 ± 0.380	0.142 UI ± 0.214	0.457 J ± 0.275	0.515 J ± 0.273	0.426 J ± 0.243		0.553 J ± 0.278

ABBREVIATIONS AND NOTES:

CCR: Coal Combustion Residuals
 CFR: Code of Federal Regulations
 ft amsl: feet above mean sea level
 MCL: Maximum Contaminant Level
 mg/L: milligram per liter
 mS/cm: millisiemen per centimeter
 mv: millivolt
 NA: Not Applicable
 NTU: Nephelometric Turbidity Units
 pCi/L: picoCurie per liter
 su: standard units
 USEPA: United States Environmental Protection Agency

QUALIFIERS:
 J: value is estimated
 J+: value is estimated with a potentially high bias
 J-: value is estimated with a potentially low bias
 R: value is rejected
 U: Not detected value is the laboratory reporting limit

- USEPA. 2016. Final Rule: Disposal of Coal Combustion Residuals from Electric Utilities. July 26. 40 CFR Part 257.
<https://www.epa.gov/coalash/coal-ash-rule>

TABLE II
SUMMARY OF ANALYTICAL RESULTS
A.B. BROWN GENERATING STATION
MOUNT VERNON, INDIANA

Location Group	Upgradient									
	CCR-BK-2	CCR-BK-2	CCR-BK-2	CCR-BK-2	CCR-BK-2	CCR-BK-2	CCR-BK-2	CCR-BK-2	CCR-BK-2	CCR-BK-2
Location Name	CCR-BK-2-20160608	CCR-BK-2-20160810	CCR-BK-2-20161027	CCR-BK-2-20161206	CCR-BK-2-20170210	CCR-BK-2-20170405	CCR-BK-2-20170606	CCR-BK-2-20170927	CCR-BK-2-20171116	
Sample Name	06/08/2016		08/10/2016		10/27/2016		12/06/2016		02/10/2017	
Sample Date	180-55607-6		180-57528-15		180-60271-7		180-61491-19		180-63446-1	
Lab Sample ID	416.46		412.21		408.69		407.90		412.89	
Water Level (ft amsl)	Baseline		Baseline		Baseline		Baseline		Baseline	
Monitoring Program										
Field Parameters										
Temperature (Deg C)	17.51	17.4	15.98	14.25	13.49	15.79	15.68	16.85	14.23	
Turbidity, Field (NTU)	-	-	-	-	-	-	-	167.49		
Dissolved Oxygen, Field (mg/L)	0.42	0.22	0.38	0.33	0.35	1.08	0.14	0.43	0.47	
Conductivity, Field (mS/cm)	0.6551	0.4173	0.40128	0.30961	0.38131	0.29739	0.41407	0.38594	0.38795	
ORP, Field (mv)	28.72	144	234.6	87.3	120.09	200.74	212.67	212.04	108.47	
Turbidity, Field (NTU)	17.85	1.751	858.51	336.44	11.66	-22.18	-1.12	-	181.78	
pH, Field (su)	6.98	6.64	6.7	6.19	6.72	6.66	6.67	6.64	6.74	
Detection Monitoring - EPA Appendix III Constituents (mg/L)										
Boron, Total	0.018 J+	0.014 U	0.02 U	0.02 U	0.08 U	0.016 U	0.021 J	0.018 J+	0.02 J	
Calcium, Total	53	39	46	36	34	45	37	37	35	
Chloride (mg/L)	12	17	17	19	12 J+	19	14	19	19	
Fluoride (mg/L)	R	0.14 J+	0.16	0.2 J+	0.14	0.16	0.13	R	0.13	
Sulfate (mg/L)	61	30 J-	28	26	25 J+	29	27	24	23 J-	
pH (lab) (su)	7.09 J	7.1 J	6.8 J	6.7 J	8.5 J	7.2 J	7 J	6.8 J	7.3 J	
Total Dissolved Solids (TDS) (mg/L)	360	260	350	260	230	240	270	320	250	
Assessment Monitoring - EPA Appendix IV Constituents (mg/L)										
Antimony, Total	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.00048 J				
Arsenic, Total	0.00032 J	0.001 U	0.0013	0.00051 J	0.00031 J	0.001 U	0.001 U	0.0035 J+	0.0028	
Barium, Total	0.041 J-	0.033	0.15	0.036 J-	0.033 J-	0.034 J-	0.035	0.048 J-	0.046 J-	
Beryllium, Total	0.001 U	0.001 U	0.0004 J	0.001 U	0.001 U	0.001 U	0.001 U	0.00018 J	0.001 U	
Cadmium, Total	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U					
Chromium, Total	0.002 U	0.002 U	0.0047	0.00076 J	0.002 UJ	0.002 U	0.002 U	R	0.0043 J+	
Cobalt, Total	0.000096 J	0.0001 J	0.0062	0.0005 U	0.0005 U	0.0005 U	0.0005 U	0.0015 J+	0.0012	
Lead, Total	0.000028 J	0.001 U	0.011	0.00057 J	0.001 U	0.001 U	0.001 U	0.0028 J+	0.0024	
Lithium, Total	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U					
Molybdenum, Total	0.0017 J	0.005 U	0.005 U	0.005 U	0.005 U	0.005 U	0.005 U	0.00062 J	0.00068 J	
Selenium, Total	0.005 U	0.005 U	0.00098 J	0.00047 J	0.005 U	0.005 U	0.005 U	0.005 U	0.005 U	
Thallium, Total	0.001 U	0.001 U	0.001 U	0.001 U	0.000059 J					
Mercury, Total	0.0002 UJ	0.0002 U	0.0001 J	0.0002 UJ	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 UJ	
Fluoride (mg/L)	R	0.14 J+	0.16	0.2 J+	0.14	0.16	0.13	R	0.13	
Radiological (pCi/L)										
Radium-226	0.102 J ± 0.0557	0.0387 U ± 0.0693	1.14 J ± 0.720	0.346 U ± 0.284	0.0539 UJ ± 0.0753	0.0198 U ± 0.0619	0.00911 UJ ± 0.0490	R	0.149 ± 0.0943	
Radium-228	0.0185 U ± 0.200	0.0797 UJ ± 0.324	0.764 U ± 0.727	R	0.163 U ± 0.253	0.102 U ± 0.198	0.144 ± 0.284	0.279 U ± 0.416	2.98 ± 0.579	
Radium-226 & 228	0.120 U ± 0.207	0.118 UJ ± 0.331	1.91 J ± 1.02	0.796 J ± 0.380	0.217 UJ ± 0.264	0.122 U ± 0.208	0.153 U ± 0.288	0.525 UJ ± 0.436	3.13 ± 0.587	

ABBREVIATIONS AND NOTES:

CCR: Coal Combustion Residuals
 CFR: Code of Federal Regulations
 ft amsl: feet above mean sea level
 MCL: Maximum Contaminant Level
 mg/L: milligram per liter
 mS/cm: millisiemen per centimeter
 mv: millivolt
 NA: Not Applicable
 NTU: Nephelometric Turbidity Units
 pCi/L: picoCurie per liter
 su: standard units
 USEPA: United States Environmental Protection Agency

QUALIFIERS:

J: value is estimated
 J+: value is estimated with a potentially high bias
 J-: value is estimated with a potentially low bias
 R: value is rejected
 U: Not detected value is the laboratory reporting limit

- USEPA. 2016. Final Rule: Disposal of Coal Combustion Residuals from Electric Utilities. July 26. 40 CFR Part 257.
<https://www.epa.gov/coalash/coal-ash-rule>

TABLE II
SUMMARY OF ANALYTICAL RESULTS
A.B. BROWN GENERATING STATION
MOUNT VERNON, INDIANA

Location Group	Downgradient								
	CCR-SP-1 CCR-SP-1-20160609 06/09/2016 180-55607-10 393.49 Baseline	CCR-SP-1 CCR-SP-1-20160809 08/09/2016 180-57528-9 393.74 Baseline	CCR-SP-1 CCR-SP-1-20161027 10/27/2016 180-60271-1 392.86 Baseline	CCR-SP-1 CCR-SP-1-20170117 01/17/2017 180-62677-1 393.23 Baseline	CCR-SP-1 CCR-SP-1-20170206 02/06/2017 180-63324-10 393.91 Baseline	CCR-SP-1 CCR-SP-1-20170404 04/04/2017 180-64974-17 393.95 Baseline	CCR-SP-1 CCR-SP-1-20170605 06/05/2017 180-67229-18 393.66 Baseline	CCR-SP-1 CCR-SP-1-20170926 09/26/2017 180-70809-17 393.51 Baseline	CCR-SP-1 CCR-SP-1-20171115 11/15/2017 180-72643-7 393.26 Detection
Field Parameters									
Temperature (Deg C)	17.3	18.78	17.41	-	15.35	15.89	16.82	18.18	16.81
Turbidity, Field (NTU)					-	-	-	-	-
Dissolved Oxygen, Field (mg/L)	0.2	0.17	0.29	-	0.06	0.04	0.01	-0.02	-0.01
Conductivity, Field (mS/cm)	1.12367	1.039	0.82285	-	0.97299	0.691	0.92488	1.17076	1.30724
ORP, Field (mv)	-69.41	-24	20	-	-25.92	-44.43	-87.99	-38.71	-85.51
Turbidity, Field (NTU)	13.23	33.26	-0.79	-	13.2	11.78	4.49	-0.14	0.07
pH, Field (su)	6.89	6.73	6.89	-	6.83	6.94	6.9	6.51	6.73
Detection Monitoring - EPA Appendix III Constituents (mg/L)									
Boron, Total	0.038 J+	0.041 J+	0.031 U	0.08 U	0.08 U	0.038 J	0.03 J	0.039 J+	0.033 J
Calcium, Total	110	110	120	120	110	130	120	140	150
Chloride (mg/L)	54	47	39	47	46	51	42	64	74
Fluoride (mg/L)	R	0.27	0.24	0.27	0.22	0.27	0.28	0.28 J+	0.28
Sulfate (mg/L)	100	67 J-	46	54	50	64	55	150	220 J-
pH (lab) (su)	6.98 J	7.2 J	6.9 J	6.6 J	7 J	7.3 J	7.1 J	7.1 J	7.4 J
Total Dissolved Solids (TDS) (mg/L)	710	620	560	580	560	570	590	730	820
Assessment Monitoring - EPA Appendix IV Constituents (mg/L)									
Antimony, Total	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U
Arsenic, Total	0.0039	0.0042	0.0042	0.0051	0.0051	0.0064	0.0058	0.013 J+	0.0054
Barium, Total	0.1 J-	0.081	0.083	0.087	0.085	0.1 J-	0.093	0.095 J-	0.12 J-
Beryllium, Total	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U
Cadmium, Total	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U
Chromium, Total	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	R	0.002 U
Cobalt, Total	0.0033	0.0031	0.0028	0.0029	0.0028	0.0027	0.0028	0.0032	0.0038
Lead, Total	R	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U
Lithium, Total	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U
Molybdenum, Total	0.0014 J	0.0014 J	0.0021 J	0.0014 J	0.0019 J	0.0005 U	0.0018 J	0.0015 J	0.0016 J
Selenium, Total	0.005 U	0.00036 J	0.005 U	0.005 U	0.005 U	0.005 U	0.005 U	0.005 U	0.005 U
Thallium, Total	0.000026 J	0.001 U	0.00093 J	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U
Mercury, Total	0.0002 UJ	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 UJ
Fluoride (mg/L)	R	0.27	0.24	0.27	0.22	0.27	0.28	0.28 J+	0.28
Radiological (pCi/L)									
Radium-226	0.393 J ± 0.105	0.264 ± 0.101	0.130 U ± 0.207	0.0940 U ± 0.0873	0.170 ± 0.109	0.134 ± 0.0915	0.166 J ± 0.0787	R	0.165 ± 0.0740
Radium-228	0.131 U ± 0.210	0.192 UI ± 0.277	0.381 U ± 0.265	0.410 U ± 0.271	0.174 U ± 0.274	-0.0357 U ± 0.241	0.185 ± 0.213	0.478 ± 0.233	0.350 U ± 0.244
Radium-226 & 228	0.525 ± 0.235	0.456 UJ ± 0.295	0.511 ± 0.336	0.504 ± 0.284	0.344 UI ± 0.294	0.134 UI ± 0.258	0.352 J ± 0.227	R	0.514 J ± 0.255

ABBREVIATIONS AND NOTES:

CCR: Coal Combustion Residuals
 CFR: Code of Federal Regulations
 ft amsl: feet above mean sea level
 MCL: Maximum Contaminant Level
 mg/L: milligram per liter
 mS/cm: millisiemen per centimeter
 mv: millivolt
 NA: Not Applicable
 NTU: Nephelometric Turbidity Units
 pCi/L: picoCurie per liter
 su: standard units
 USEPA: United States Environmental Protection Agency

QUALIFIERS:
 J: value is estimated
 J+: value is estimated with a potentially high bias
 J-: value is estimated with a potentially low bias
 R: value is rejected
 U: Not detected value is the laboratory reporting limit

- USEPA. 2016. Final Rule: Disposal of Coal Combustion Residuals from Electric Utilities. July 26. 40 CFR Part 257.
<https://www.epa.gov/coalash/coal-ash-rule>

TABLE II
SUMMARY OF ANALYTICAL RESULTS
A.B. BROWN GENERATING STATION
MOUNT VERNON, INDIANA

Location Group	Downgradient									
	CCR-SP-2	CCR-SP-2								
Location Name	CCR-SP-2-20160609	CCR-SP-2-20160809	CCR-SP-2-20161026	CCR-SP-2-20170126	CCR-SP-2-20170206	CCR-SP-2-20170404	CCR-SP-2-20170605	CCR-SP-2-20170926	CCR-SP-2-20171115	
Sample Name	06/09/2016		08/09/2016		10/26/2016		01/26/2017		02/06/2017	
Sample Date	180-55607-11		180-57528-10		180-60193-12		180-62992-1		180-63324-11	
Lab Sample ID	393.61		393.92		392.23		393.53		393.73	
Water Level (ft amsl)	Baseline		Baseline		Baseline		Baseline		Baseline	
Monitoring Program										
Field Parameters										
Temperature (Deg C)	16.74	18.73	18.69	-	15.89	15.71	16.39	19.24	17.38	
Turbidity, Field (NTU)	-	-	-	-	-	-	-	-	-	
Dissolved Oxygen, Field (mg/L)	0.14	0.15	0.08	-	0.14	0.02	0.06	-0.01	-0.02	
Conductivity, Field (mS/cm)	1.08	1.078	0.97799	-	1.43635	1.54536	1.52661	1.57587	1.59103	
ORP, Field (mv)	29	93	0	-	105.02	28.2	54.35	85.1	16.7	
Turbidity, Field (NTU)	19.14	33.01	10.16	-	49.45	1.51	6.38	3.42	35.67	
pH, Field (su)	6.95	6.82	6.92	-	6.87	6.95	6.95	6.68	6.83	
Detection Monitoring - EPA Appendix III Constituents (mg/L)										
Boron, Total	0.08	0.093 J+	0.11 J+	0.19	0.21	0.34	0.37	0.32 J+	0.24	
Calcium, Total	110	120	140	160	170	190	170	170	180	
Chloride (mg/L)	46	42	50	67	67	71	63	72	73	
Fluoride (mg/L)	0.38 J+	0.32	0.35	0.33	0.34	0.38	0.37	0.34 J+	0.31	
Sulfate (mg/L)	180	160 J-	190 J-	360	370	430	390	470	460 J-	
pH (lab) (su)	7.05 J	7.5 J	7.1 J	7 J	7.2 J	7.4 J	7.2 J	7.1 J	7.4 J	
Total Dissolved Solids (TDS) (mg/L)	750	710	780	970	1000	1100	1200	1200	1100	
Assessment Monitoring - EPA Appendix IV Constituents (mg/L)										
Antimony, Total	0.002 U									
Arsenic, Total	0.0046 J	0.0016	0.00064 J	0.0013	0.0016	0.00031 J	0.00027 J	0.0077 J+	0.0014 J+	
Barium, Total	0.082 J-	0.084	0.089 J-	0.12	0.13	0.13 J-	0.14	0.12 J-	0.14 J-	
Beryllium, Total	0.001 U									
Cadmium, Total	0.001 U	0.001 U	0.001 U	0.00098 J	0.00011 J	0.001 U	0.001 U	0.001 U	0.001 U	
Chromium, Total	0.002 U	0.0012 J	0.00047 J	0.0014 J	0.0012 J	0.002 U	0.002 U	R	0.002 U	
Cobalt, Total	0.0011	0.0014	0.00081	0.00083	0.00084	0.00039 J	0.00045 J	0.00086	0.0012	
Lead, Total	R	0.00091 J	0.00033 J	0.00078 J	0.00097 J	0.001 U	0.001 U	0.001 U	0.0008 J	
Lithium, Total	0.05 U	0.05 U	0.05 U	0.011 J	0.05 U					
Molybdenum, Total	0.0016 J	0.0015 J	0.005 U	0.0012 J	0.0014 J	0.005 U	0.0012 J	0.0015 J	0.0012 J	
Selenium, Total	0.005 U	0.0063 J	0.005 U							
Thallium, Total	0.001 U	0.001 U	0.00049 J	0.001 U						
Mercury, Total	0.0002 UJ	0.0002 U	0.0002 UJ	0.0002 U						
Fluoride (mg/L)	0.38 J+	0.32	0.35	0.33	0.34	0.38	0.37	0.34 J+	0.31	
Radiological (pCi/L)										
Radium-226	0.171 J ± 0.0737	0.265 ± 0.129	0.189 ± 0.237	R	0.256 ± 0.129	0.112 ± 0.0818	0.172 J ± 0.0817	R	0.242 ± 0.0951	
Radium-228	0.103 U ± 0.219	0.581 U ± 0.562	0.241 U ± 0.253	0.693 ± 0.285	0.0457 U ± 0.282	0.798 ± 0.379	0.100 ± 0.199	0.699 ± 0.293	0.405 U ± 0.285	
Radium-226 & 228	0.275 U ± 0.231	0.846 U ± 0.577	0.431 ± 0.347	0.887 J+ ± 0.312	0.302 UJ ± 0.310	0.910 ± 0.388	0.273 UJ ± 0.215	R	0.647 J ± 0.300	

ABBREVIATIONS AND NOTES:

CCR: Coal Combustion Residuals

CFR: Code of Federal Regulations

ft amsl: feet above mean sea level

MCL: Maximum Contaminant Level

mg/L: milligram per liter

mS/cm: millisiemen per centimeter

mV: millivolt

NA: Not Applicable

NTU: Nephelometric Turbidity Units

pCi/L: picoCurie per liter

su: standard units

USEPA: United States Environmental Protection Agency

QUALIFIERS:

J: value is estimated

J+: value is estimated with a potentially high bias

J-: value is estimated with a potentially low bias

R: value is rejected

U: Not detected value is the laboratory reporting limit

- USEPA. 2016. Final Rule: Disposal of Coal Combustion Residuals from Electric Utilities. July 26. 40 CFR Part 257.

<https://www.epa.gov/coalash/coal-ash-rule>

TABLE II
SUMMARY OF ANALYTICAL RESULTS
A.B. BROWN GENERATING STATION
MOUNT VERNON, INDIANA

Location Group	Downgradient								
	CCR-SP-3 CCR-SP-3-20160609 06/09/2016 180-55607-12 398.81 Baseline	CCR-SP-3 CCR-SP-3-20160809 08/09/2016 180-57528-11 397.25 Baseline	CCR-SP-3 CCR-SP-3-20161027 10/27/2016 180-60193-11 392.77 Baseline	CCR-SP-3 CCR-SP-3-20170117 01/17/2017 180-62677-3 398.41 Baseline	CCR-SP-3 CCR-SP-3-20170206 02/06/2017 180-63324-12 398.92 Baseline	CCR-SP-3 CCR-SP-3-20170404 04/04/2017 180-64974-19 398.61 Baseline	CCR-SP-3 CCR-SP-3-20170606 06/06/2017 180-67229-9 396.10 Baseline	CCR-SP-3 CCR-SP-3-20170926 09/26/2017 180-70809-25 390.91 Baseline	CCR-SP-3 CCR-SP-3-20171115 11/15/2017 180-72643-9 394.01 Detection
Field Parameters									
Temperature (Deg C)	16.72	18.6	17.88	-	14.5	14.85	15.29	24.11	16.63
Turbidity, Field (NTU)	-	-	-	-	-	-	-	-	-
Dissolved Oxygen, Field (mg/L)	0.12	0.13	0.06	-	0.05	0.04	0.05	0.99	0.01
Conductivity, Field (mS/cm)	0.67071	0.711	605.64	-	0.7003	1.04504	0.6691	0.69142	0.701
ORP, Field (mv)	-91.32	-100	-70	-	-100.6	-39.69	-125.53	-46.17	-143.1
Turbidity, Field (NTU)	17.26	176.1	256.05	-	20.72	13.82	25.67	19.05	77.41
pH, Field (su)	7.05	6.95	7.08	-	7.01	6.93	7.09	6.8	6.97
Detection Monitoring - EPA Appendix III Constituents (mg/L)									
Boron, Total	0.023 J+	0.027 U	0.028 U	0.08 U	0.08 U	0.026 J	0.042 J	0.024 J+	0.019 J
Calcium, Total	76	84	92	86	85	96	88	83	86
Chloride (mg/L)	4.1 J+	3.4	4.7	4.7	4	4.3	2.9	5.1	4.1
Fluoride (mg/L)	0.38 J+	0.33	0.41	0.39	0.4	0.38	0.34	0.38 J+	0.41
Sulfate (mg/L)	R	1 U	0.68 J-	1 U	1.1	0.81 J	1 U	4.4	0.63 J-
pH (lab) (su)	7.27 J	7.6 J	7.1 J	6.6 J	7.3 J	7 J	7.2 J	7.1 J	7.6 J
Total Dissolved Solids (TDS) (mg/L)	400	390	390	370	380	380	400	400	370
Assessment Monitoring - EPA Appendix IV Constituents (mg/L)									
Antimony, Total	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U	0.002 U
Arsenic, Total	0.016	0.026	0.043	0.019	0.024	0.017	0.024	0.012 J+	0.035
Barium, Total	0.072 J-	0.069	0.11 J-	0.077	0.078	0.069 J-	0.072	0.064 J-	0.074 J-
Beryllium, Total	0.001 U	0.001 U	0.00029 J	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U
Cadmium, Total	0.001 U	0.001 U	0.00015 J	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U
Chromium, Total	0.002 U	0.002 U	0.0096	0.002 U	0.002 U	0.002 U	0.002 U	R	0.002 U
Cobalt, Total	0.0011	0.001	0.0054	0.00072	0.0008	0.00084	0.00067	0.00049 J	0.00066
Lead, Total	R	0.00013 J	0.0061	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U
Lithium, Total	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U	0.05 U
Molybdenum, Total	0.0046 J	0.0051	0.0062	0.0051	0.0055	0.005 U	0.005	0.0031 J	0.0057
Selenium, Total	0.005 U	0.005 U	0.00042 J+	0.005 U	0.005 U	0.005 U	0.005 U	0.005 U	0.005 U
Thallium, Total	0.000024 J	0.001 U	0.00014 J	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U	0.001 U
Mercury, Total	0.0002 UJ	0.0002 U	0.0002 UJ	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 U	0.0002 UJ
Fluoride (mg/L)	0.38 J+	0.33	0.41	0.39	0.4	0.38	0.34	0.38 J+	0.41
Radiological (pCi/L)									
Radium-226	0.198 J ± 0.0738	0.194 ± 0.0788	0.661 U ± 0.654	0.0991 U ± 0.107	0.151 ± 0.0962	0.132 ± 0.0878	R	R	0.123 ± 0.0675
Radium-228	0.251 U ± 0.227	-0.0623 UI ± 0.296	0.239 U ± 0.573	0.140 U ± 0.256	-0.00781 U ± 0.215	0.206 U ± 0.278	0.166 ± 0.212	-0.0314 U ± 0.230	0.293 U ± 0.230
Radium-226 & 228	0.449 ± 0.239	0.131 UI ± 0.307	0.900 U ± 0.870	0.239 U ± 0.277	0.151 UI ± 0.236	0.338 UI ± 0.292	0.335 UI ± 0.229	0.23 UI ± 0.247	0.416 J ± 0.240

ABBREVIATIONS AND NOTES:

CCR: Coal Combustion Residuals
 CFR: Code of Federal Regulations
 ft amsl: feet above mean sea level
 MCL: Maximum Contaminant Level
 mg/L: milligram per liter
 mS/cm: millisiemen per centimeter
 mv: millivolt
 NA: Not Applicable
 NTU: Nephelometric Turbidity Units
 pCi/L: picoCurie per liter
 su: standard units
 USEPA: United States Environmental Protection Agency

QUALIFIERS:
 J: value is estimated
 J+: value is estimated with a potentially high bias
 J-: value is estimated with a potentially low bias
 R: value is rejected
 U: Not detected value is the laboratory reporting limit

- USEPA. 2016. Final Rule: Disposal of Coal Combustion Residuals from Electric Utilities. July 26. 40 CFR Part 257.
<https://www.epa.gov/coalash/coal-ash-rule>

FIGURES



LEGEND

- UPGRADIENT MONITORING WELL
- DOWNGRADIENT MONITORING WELL
- TOPOGRAPHIC DIVIDE

NOTES

- LOCATIONS DERIVED FROM THREE I DESIGN DATA.
- ALL LOCATIONS AND DIMENSIONS ARE APPROXIMATE.
- AERIAL IMAGERY SOURCE: ESRI



0 500 1,000
SCALE IN FEET

HALEY ALDRICH

VECTREN CORPORATION
A.B. BROWN GENERATING STATION
8511 WELBORN ROAD
MOUNT VERNON, IN 47620

MONITORING WELL NETWORK
SEDIMENTATION POND

JANUARY 2018

FIGURE 1