

Notice of Establishment of an Assessment Monitoring Program

F.B. Culley Generating Station – East Ash Pond

August 15, 2018

40 CFR §257.94(e)(3)

As required by 40 CFR §257.94(e)(3), notification is hereby provided that an assessment monitoring program has been established for the F.B. Culley East Ash Pond. A statistically significant increase (SSI) over background levels for one or more constituents listed in Appendix III has been determined for the CCR unit. Per 40 CFR §257.94(e)(2), a successful demonstration was not completed within 90 days of the SSI determination, and an assessment program was initiated. The assessment monitoring program has been established to meet the requirements of 40 CFR §257.95.